

# **TOWNSHIP PARK WATER COMPANY (PWS 7100155) SOURCE WATER ASSESSMENT FINAL REPORT**

---

**March 25, 2002**



## **State of Idaho Department of Environmental Quality**

**Disclaimer:** This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

## Executive Summary

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the Act. This assessment is based on a land use inventory of the designated assessment area and sensitivity factors associated with the wells and aquifer characteristics.

This report, *Source Water Assessment for the Township Park Water Company*, describes the public drinking water system, the boundaries of the zones of water contribution, and the associated potential contaminant sources located within these boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The Township Park Water Company drinking water system consists of two ground water wells. Wells W and E have high susceptibility ratings for inorganic, volatile organic, synthetic organic, and microbial contamination due to aquifer properties, high county wide agricultural chemical use, and the presence of potential sources of contaminants in the source water assessment area. Neither well has recorded concentrations of microbial contamination, volatile organic contamination (VOC), or synthetic organic contamination (SOC) during any water chemistry tests thus far.

In May 1997, the inorganic contaminants (IOCs) barium and fluoride were detected in a water sample collected from the well W and E manifold at concentrations well below the Maximum Contaminant Level (MCL). In July 2000, the IOC arsenic was detected in a water sample collected from the well W and E manifold at a concentration of 9 parts per billion (ppb). In October 2001, the U.S. EPA reduced the arsenic MCL from 50 ppb to 10 ppb, giving public water systems until 2006 to comply with the new standard. The Township Park Water Company should be aware that the natural arsenic levels in the area could pose a health hazard. Nitrate concentrations detected in water samples collected from the well W and E manifold are below the MCL for nitrate.

Despite the lack of significant contamination in the well water, the Township Park Water Company should be aware that the potential for contamination still exists. Surrounding agricultural land use practices, high county wide agricultural chemical use, and multiple potential contaminant sources pose a potential threat to the quality of the source water for the two Township Park Water Company wells. In addition, the source water assessment areas for the Township Park Water Company wells cross an organics priority area for the synthetic organic pesticide Atrazine.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources. If the system should need to expand in the future, new well sites should be located in areas with as few potential sources of contamination as possible, and the site should be reserved and protected for this specific use.

For the Township Park Water Company, drinking water protection activities should focus on correcting any deficiencies outlined in the sanitary survey (an inspection conducted every five years with the purpose of determining the physical condition of a water system’s components and its capacity). If concentrations of nitrate detected in the source water continue to increase the Township Park Water

Company should investigate various systems like ion exchange, reverse osmosis, or activated alumina that could be used to treat this chemical. Additionally, there should be a focus on the implementation of practices aimed at reducing the leaching of agricultural chemicals from agricultural land within the designated source water areas and awareness of the potential contaminant sources in the area. Since much of the designated protection areas are outside the direct jurisdiction of the Township Park Water Company, it is important that partnerships with state and local agencies, and industry groups be established. These collaboration efforts are critical to the success of drinking water protection. Both wells should adhere to sanitary survey standards regarding wellhead protection.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan as the delineations contain large urban land uses. There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the U.S. Environmental Protection Agency. As there are many transportation corridors through the delineations, the Department of Transportation should be involved in protection activities. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil Conservation District, and the Natural Resources Conservation Service.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking water protection plan, be they regulatory in nature (i.e. zoning, permitting) or non-regulatory in nature (i.e. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Idaho Falls Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

# SOURCE WATER ASSESSMENT FOR THE TOWNSHIP PARK WATER COMPANY, BONNEVILLE COUNTY, IDAHO

## Section 1. Introduction - Basis for Assessment

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are attached. The list of significant potential contaminant source categories and their rankings used to develop the assessment also is attached.

### Background

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area and sensitivity factors associated with the wells and aquifer characteristics.

### Level of Accuracy and Purpose of the Assessment

Since there are over 2,900 public water sources in Idaho, there is limited time and resources to accomplish the assessments. All assessments must be completed by May of 2003. An in-depth, site-specific investigation of each significant potential source of contamination is not possible. **Therefore, this assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The ultimate goal of the assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. The Idaho Department of Environmental Quality (DEQ) recognizes that pollution prevention activities generally require less time and money to implement than treatment of a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a drinking water protection program should be determined by the local community based on its own needs and limitations. Wellhead or drinking water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

## **Section 2. Conducting the Assessment**

### **General Description of the Source Water Quality**

The public drinking water system for the Township Park Water Company is comprised of two ground water wells that serve approximately 54 people through 13 connections. The wells are located south of Idaho Falls, Idaho (Figure 1). An SOC priority area for the pesticide Atrazine crosses the delineated source water assessment areas. In addition, county wide agricultural chemical use is high for this area.

The main water chemistry issue with the ground water quality is increasing concentrations of nitrate in the source water. From April 1997 to February 2000, nitrate was detected in six water samples collected from the well W and E manifold at concentrations ranging from 2.78 parts per million (ppm) to 5.01 ppm. These detections are below the MCL for nitrate of 10 ppm. In May 1997, the IOCs barium and fluoride were detected in a water sample collected from the well W and E manifold at concentrations of 0.13 ppm and 0.37 ppm, respectively. These detections are well below the MCLs for barium and fluoride of 2.0 ppm and 4.0 ppm, respectively. In July 2000, the IOC arsenic was detected in a water sample collected from the well W and E manifold at a concentration of 9 parts per billion (ppb). Though this detection was well below the MCL for arsenic of 50 ppb at the time, the Safe Drinking Water Act required the EPA to revise the MCL for arsenic. In October 2001, EPA published a new standard for arsenic in drinking water that requires public water supplies to reduce arsenic to 10 ppb by 2006.

### **Defining the Zones of Contribution – Delineation**


The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time-of-travel (TOT) zones (zones indicating the number of years necessary for a particle of water to reach a well) for water in the aquifer. DEQ contracted with Washington Group, International (WGI) to perform the delineations using the refined computer model, Wellhead Analytical Element Model (WHAEM) approved by the EPA in determining the source approved by the EPA in determining the 3-year (Zone 1B), 6-year (Zone 2), and 10-year (Zone 3) TOT for water associated with the Eastern Snake River Plain (ESRP) aquifer in the vicinity of the Township Park Water Company wells. The computer model used site specific data, assimilated by WGI from a variety of sources including the Township Park Water Company operator report, other local area well logs, and hydrogeologic reports (detailed below).

The ESRP is a northeast trending basin located in southeastern Idaho. Ten thousand square miles of the basin are primarily filled with highly fractured layered Quaternary basalt flows of the Snake River Group, which are intercalated with terrestrial and lake deposited sediments along the margins (Garabedian, 1992, p. 5). Individual basalt flows range from 10 to 50 feet in thickness and average 20 to 25 feet (Lindholm, 1996, p. 14). Basalt is thickest in the central part of the eastern plain and thins toward the margins. Whitehead (1992, p. 9) estimates the total thickness of the flows to be as great as 5,000 feet. A thin layer (0 to 100 feet) of windblown and fluvial sediments overlies the basalt.

The plain is bound on the northeast by rocks of the Yellowstone Group (mainly rhyolite) and Idavada Volcanics to the southwest. The Snake River flows along part of the southern boundary and is the only drainage that leaves the plain. Rivers and streams entering the plain from the south are tributary to the Snake River. Rivers entering from the north vanish into the basalts of the Snake River Plain aquifer.

The layered basalts of the Snake River Group host one of the most productive aquifers in the United States. The aquifer is generally considered unconfined, yet it may be locally confined in some areas because of inter-bedded clay and dense unfractured basalt (Whitehead, 1992, p. 26). Whitehead (1992, p.

**FIGURE 1 - Geographic Location of Township Park Water Company,  
PWS 7100155, E & W Wells**



22) reports that well yields of 2,000 to 3,000 gallons per minute (gpm) are common for wells open to less than 100 feet of the aquifer. Lindholm (1996, p. 18) estimates aquifer thickness to range from several hundred feet near the plain's margin to thousands of feet near the center.

The majority of aquifer recharge results from surface water irrigation activities (incidental recharge), which divert water from the Snake River and its tributaries (Ackerman, 1995, p. 4, and Garabedian, 1992, p. 11). Natural recharge occurs through stream losses, direct precipitation, and tributary basin underflow.

Regional ground water flow is to the southwest paralleling the basin (Cosgrove et al., 1999, p. 21; deSonneville, 1972, p. 78; Garabedian, 1992, p. 48; and Lindholm, 1996, p. 23). Ground water flow direction at the local scale is thought to be highly variable due to preferential flow paths through the fractured and layered basalts.

The delineated source water assessment areas for the Township Park Water Company wells can best be described as corridors approximately 0.2 miles wide at the wellhead to 3.4 miles wide where they intersect the Snake River, 21.2 miles to the northeast (Figures 2 and 3). Each of the delineations only has the 3-year and 6-year TOT because the Snake River is assessed to be the main source of the wells' water. The actual data used by WGI in determining the source water assessment delineation areas are available from DEQ upon request.

### **Identifying Potential Sources of Contamination**

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources. The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of groundwater contamination. The locations of potential sources of contamination within the delineation areas were obtained by field surveys conducted by DEQ and from available databases.

Land use within the immediate area of the Township Park Water Company wellheads consists of residential and agricultural land use, while the surrounding area is predominantly irrigated agriculture with some urban land use where the delineation intersects Idaho Falls. A major transportation corridor (Highway 26) crosses the source water assessment areas of the wells

It is important to understand that a release may never occur from a potential source of contamination provided they are using best management practices. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, including educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

### **Contaminant Source Inventory Process**

A two-phased contaminant inventory of the study area was conducted in May 2001. The first phase involved identifying and documenting potential contaminant sources within the Township Park Water

Company Source Water Assessment Areas (Figures 2 & 3) through the use of computer databases and Geographic Information System (GIS) maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the operator to identify and add any additional potential sources in the area.

The delineated source water areas encompass corridors of land between the well sites and the Snake River. The delineated source water assessment areas for well W (Table 1, Figure 2) and well E (Table 1, Figure 3) contain one hundred (100) potential contaminant sources. These sources include Highway 26, Willow Creek, and the Snake River. There are also numerous irrigation canals that cross the delineations. If an accidental spill occurred on the highway, Willow Creek, the Snake River, or the irrigation canals, IOCs, VOCs, SOC, or microbial contaminants could be added to the aquifer system due to the fractured nature of the basalt aquifer.

**Table 1. The Township Park Water Company Wells W and E Potential Contaminant Inventory**

Site #	Source Description	TOT Zone <sup>1</sup>	Source of Information	Potential Contaminants <sup>2</sup>
1	UST <sup>3</sup> site, Gas Station; Closed	0-3	Database Search	VOC, SOC
2	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
3	UST site, Farm; Open	0-3	Database Search	VOC, SOC
4	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
5	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
6	UST site, Farm; Closed	0-3	Database Search	VOC, SOC
7	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
8	UST site, Gas Station; Closed	0-3	Database Search	VOC, SOC
9	UST site, Other; Closed	0-3	Database Search	VOC, SOC
10	UST site, Other; Closed	0-3	Database Search	VOC, SOC
11	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
12	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
13	UST site, Other; Closed	0-3	Database Search	VOC, SOC
14	UST site, Gas Station; Open	0-3	Database Search	VOC, SOC
15	Dairy, <=200 cows	0-3	Database Search	IOC, Microbes
16	Dairy, <=200 cows	0-3	Database Search	IOC, Microbes
17	Dairy, <=200 cows	0-3	Database Search	IOC, Microbes
18	Dairy, <=200 cows	0-3	Database Search	IOC, Microbes
19	Dairy, <=200 cows	0-3	Database Search	IOC, Microbes
20	Dairy, <=200 cows	0-3	Database Search	IOC, Microbes
21	Pest Control	0-3	Database Search	IOC, VOC, SOC
22	Limousine Service	0-3	Database Search	IOC, VOC, SOC
23	Plumbing Drain & Sewer Cleaning	0-3	Database Search	IOC, Microbes
24	Laboratories-Medical	0-3	Database Search	IOC, Microbes
25	Hospitals	0-3	Database Search	IOC, Microbes
26	Packaging Machinery-Wholesale	0-3	Database Search	IOC, VOC, SOC
27	Trucking-Liquid & Dry Bulk	0-3	Database Search	IOC, VOC, SOC
28	Paving Contractors	0-3	Database Search	IOC, VOC, SOC
29	Water Treatment Equip Service & Supplies	0-3	Database Search	IOC, VOC, SOC
30	Tire-Dealers-Retail	0-3	Database Search	IOC, VOC, SOC
31	Building Contractors	0-3	Database Search	IOC, VOC, SOC
32	Automobile Parts & Supplies-Retail	0-3	Database Search	IOC, VOC, SOC
33	Photo Finishing-Retail	0-3	Database Search	IOC, VOC, SOC
34	Car Washing & Polishing	0-3	Database Search	IOC, VOC, SOC
35	Veterinarians	0-3	Database Search	IOC, Microbes
36	Labels-Paper (Manufacturers)	0-3	Database Search	IOC, VOC, SOC



37	Cleaners	0-3	Database Search	VOC
38	Veterinarians	0-3	Database Search	IOC, Microbes
39	General Contractors	0-3	Database Search	IOC, VOC, SOC
40	Tile-Ceramic-Contractors & Dealers	0-3	Database Search	IOC
41	Water Treatment Equip Service & Supplies	0-3	Database Search	IOC, VOC, SOC
42	Hospitals	0-3	Database Search	IOC, SOC, Microbes
43	Plastics & Plastic Products	0-3	Database Search	IOC, VOC, SOC
44	Typesetting (Manufacturers)	0-3	Database Search	IOC, VOC, SOC
45	Concrete Contractors	0-3	Database Search	IOC, VOC, SOC
46	Livestock-Dealers (Wholesale)	0-3	Database Search	IOC, Microbes
47	Landscape Contractors	0-3	Database Search	IOC, VOC, SOC
48	Farms	0-3	Database Search	IOC, SOC, Microbes
49	Laboratories-Dental	0-3	Database Search	IOC, Microbes
50	Photo Finishing-Retail	0-3	Database Search	IOC, VOC
51	Pest Control	0-3	Database Search	IOC, VOC, SOC
52	Paint-Retail	0-3	Database Search	IOC, VOC, SOC
53	Automobile Detail	0-3	Database Search	IOC, VOC, SOC
54	General Contractors	0-3	Database Search	IOC, VOC, SOC
55	Home Builders	0-3	Database Search	IOC, VOC, SOC
56	Veterinarians	0-3	Database Search	IOC, Microbes
57	Photographers-Portrait	0-3	Database Search	IOC, VOC
58	Veterinarians	0-3	Database Search	IOC, Microbes
59	Laboratories-Medical	0-3	Database Search	IOC, VOC, SOC, Microbes
60	Car Washing & Polishing	0-3	Database Search	IOC, VOC, SOC
61	Electric Equipment & Supplies-Wholesale	0-3	Database Search	IOC, VOC, SOC
62	Painters	0-3	Database Search	IOC, VOC, SOC
63	Laboratories-Medical	0-3	Database Search	IOC, VOC, SOC, Microbes
64	X-Ray Laboratories-Medical	0-3	Database Search	IOC, VOC, SOC
65	Meat Processing	0-3	Database Search	IOC, VOC, Microbes
66	General Contractors	0-3	Database Search	IOC, VOC, SOC
67	Automobile Repairing & Service	0-3	Database Search	IOC, VOC, SOC
68	Publishers-Directory & Guide	0-3	Database Search	IOC, VOC
69	Printers	0-3	Database Search	IOC, VOC
70	Automobile Lubrication Service	0-3	Database Search	IOC, VOC, SOC
71	Automobile Repairing & Service	0-3	Database Search	IOC, VOC, SOC
72	Dairies	0-3	Database Search	IOC, Microbes
73	Laboratories-Dental	0-3	Database Search	IOC, Microbes
74	Sand & Gravel Mine	0-3	Database Search	IOC, VOC, SOC
75	Sand & Gravel Mine	0-3	Database Search	IOC, VOC, SOC
76	Sand & Gravel Mine	0-3	Database Search	IOC, VOC, SOC
77	Deep Injection Well, Active	0-3	Database Search	IOC, VOC, SOC
78	Deep Injection Well, Active	0-3	Database Search	IOC, VOC, SOC
79	SARA <sup>4</sup> site, Gasoline Service Station	0-3	Database Search	VOC, SOC
80	SARA site, Well No. 8	0-3	Database Search	IOC, VOC, SOC, Microbes
81	SARA site, Gasoline Service Station	0-3	Database Search	VOC, SOC
82	SARA site, Maverik	0-3	Database Search	VOC, SOC
83	SARA site, US West Communications	0-3	Database Search	IOC, VOC, SOC
84	Recharge, Unused	0-3	Database Search	IOC, VOC, SOC, Microbes
85	Recharge, Unused	0-3	Database Search	IOC, VOC, SOC, Microbes
86	AST <sup>5</sup> , Gasoline and Diesel	0-3	Database Search	VOC, SOC
87	Landfill, Municipal, Closed	0-3	Database Search	IOC, VOC, SOC, Microbes
88	UST site, Farm; Closed	3-6	Database Search	VOC, SOC

89	Dairy, <=200 cows	3-6	Database Search	IOC, Microbes
90	Potatoes-Processed	3-6	Database Search	IOC, VOC, SOC, Microbes
91	NPDES <sup>6</sup> , site, Municipal discharge	3-6	Database Search	IOC, VOC, SOC, Microbes
92	Sand & Gravel mine	3-6	Database Search	IOC, VOC, SOC
93	SARA site, Idaho Pacific Corporation	3-6	Database Search	IOC, VOC, SOC, Microbes
94	Recharge, Unused	3-6	Database Search	IOC, VOC, SOC, Microbes
95	Recharge, Unused	3-6	Database Search	IOC, VOC, SOC, Microbes
96	Recharge, Unused	3-6	Database Search	IOC, VOC, SOC, Microbes
97	Wlap <sup>7</sup> , Potato Processing	3-6	Database Search	IOC, VOC, SOC, Microbes
	Highway 26	0-3	GIS Map	IOC, VOC, SOC, Microbes
	Willow Creek	0-3	GIS Map	IOC, VOC, SOC, Microbes
	Snake River	3-6	GIS Map	IOC, VOC, SOC, Microbes

<sup>1</sup> TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead

<sup>2</sup> IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

<sup>3</sup> UST = Underground Storage Tank


<sup>4</sup> SARA = Superfund Amendments and Reauthorization Act

<sup>5</sup> AST = Aboveground Storage Tank

<sup>6</sup> NPDES = National Pollution Discharge Elimination System

<sup>7</sup> Wlap = wastewater land application

Figure 2. Township Park Water Co. Delineation Map and Pontential Contaminant Source Locations




**PWS# 7100155**  
**W Well**

MAR 28 2001, 10:23:40



Figure 3. Township Park Water Co. Delineation Map and Pontential Contaminant Source Locations



## Section 3. Susceptibility Analyses

Each well's susceptibility to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. The following summaries describe the rationale for the susceptibility ranking.

### Hydrologic Sensitivity

The hydrologic sensitivity of a well is dependent upon four factors: the surface soil composition, the material in the vadose zone (between the land surface and the water table), the depth to first ground water, and the presence of a 50-foot thick fine-grained zone above the producing zone of the well. Slowly draining soils such as silt and clay typically are more protective of ground water than coarse-grained soils such as sand and gravel. Similarly, fine-grained sediments in the subsurface and a water depth of more than 300 feet protect the ground water from contamination.

Hydrologic sensitivity is high for both wells (Table 2). This is a result of the soils being in the moderately to well-drained class, the fact that the water table is less than 300 feet from the surface, and the lack of laterally extensive low-permeability units to retard the downward movement of contaminants.

### Well Construction

Well construction directly affects the ability of the well to protect the aquifer from contaminants. System construction scores are reduced when information shows that potential contaminants will have a more difficult time reaching the intake of the well. Lower scores imply a system is less vulnerable to contamination. For example, if the well casing and annular seal both extend into a low permeability unit, then the possibility of contamination is reduced and the system construction score goes down. If the highest production interval is more than 100 feet below the water table, then the system is considered to have better buffering capacity. If the wellhead and surface seal are maintained to standards, as outlined in sanitary surveys, then contamination down the well bore is less likely. If the well is protected from surface flooding and is outside the 100-year floodplain, then contamination from surface events is reduced.

Both wells have moderate system construction scores. According to the 1996 Sanitary Survey, both wells have maintained wellheads and surface seals. Both wells are located outside of the 100-year floodplain and are protected from surface flooding.

The well logs indicate that the casings and annular seals of both wells were extended into low permeability units. However, the wells do not meet current public water system (PWS) construction standards due to the lack of a pump test for both wells and the casing thicknesses. The Idaho Department of Water Resources *Well Construction Standards Rules* (1993) require all PWSs to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works* (1997) during construction. Table 1 of the *Recommended Standards for Water Works* (1997) lists the required steel casing thickness for various diameter wells. Eight-inch diameter well casing requires a casing thickness of at least 0.322 inches and six-inch diameter well casing requires a casing thickness of

at least 0.280 inches. The Township Water Company wells were constructed with 0.250-inch thick casing.

### Potential Contaminant Source and Land Use

The wells rate high for IOCs (i.e. nitrates, arsenic), VOCs (i.e. petroleum products), and SOC (i.e. pesticides), and moderate for microbial contaminants (i.e. bacteria). Agricultural land use, high county wide agricultural chemical use, and multiple potential contaminant sources in the delineated source water areas account for the potential contaminant inventory rating.

Both wells fall within the SOC priority area for the pesticide Atrazine. The wells are also in a county with high levels of nitrogen fertilizer use, high herbicide use, and high total agricultural chemical use. Fortunately, no significant water chemistry problems have been recorded in the finished well water thus far.

### Final Susceptibility Ranking

A detection above a drinking water standard MCL or a detection of total coliform bacteria or fecal coliform bacteria at the wellhead will automatically give a high susceptibility rating to a well despite the land use of the area because a pathway for contamination already exists. Hydrologic sensitivity and system construction scores are heavily weighted in the final scores. Having multiple potential contaminant sources in the 0 to 3-year time of travel zone (Zone 1B) and agricultural land contribute greatly to the overall ranking. In terms of total susceptibility, both wells rate high for all categories.

**Table 2. Summary of The Township Park Water Company Susceptibility Evaluation**

Well	Susceptibility Scores <sup>1</sup>									
	Hydrologic Sensitivity	Contaminant Inventory				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
Well W	H	H	H	H	M	M	H	H	H	H
Well E	H	H	H	H	M	M	H	H	H	H

<sup>1</sup>H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility,

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

### Susceptibility Summary

Aquifer properties, intense agricultural practices, the high county wide use of agricultural chemicals, and the presence of multiple potential contaminant sources all contribute to the high susceptibility ratings. Though there are no significant water chemistry problems recorded for the source water to date, there have been detections in the finished well water of the IOCs arsenic, barium, fluoride and nitrate at levels below the current MCL. Both wells fall within the SOC priority area for the pesticide Atrazine. No VOCs or SOCs have been detected in the well water thus far.

## **Section 4. Options for Drinking Water Protection**

The susceptibility assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

An effective drinking water protection program is tailored to the particular local drinking water protection area. A community with a fully developed drinking water protection program will incorporate many strategies. For the Township Park Water Company, drinking water protection activities should focus on correcting any deficiencies outlined in the sanitary survey. If concentrations of nitrate and arsenic detected in the source water continue to increase, the Township Park Water Company should investigate various engineering control systems that could be used to treat these chemicals. Additionally, there should be a focus on the implementation of practices aimed at reducing the leaching of agricultural chemicals from agricultural land within the designated source water areas and awareness of the potential contaminant sources in the area. Since much of the designated protection areas are outside the direct jurisdiction of the Township Park Water Company, it is important that partnerships with state and local agencies, and industry groups be established. These collaboration efforts are critical to the success of source water protection. Both wells should adhere to sanitary survey standards regarding wellhead protection. Continued vigilance in keeping the wells protected from surface flooding can also keep the potential for contamination reduced.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan as the delineations contain large urban land uses. There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the EPA. As there are many transportation corridors through the delineations, the Department of Transportation should be involved in protection activities. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil Conservation District, and the Natural Resources Conservation Service.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking water protection plan, be they regulatory in nature (i.e. zoning, permitting) or non-regulatory in nature (i.e. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Idaho Falls Regional Office of the DEQ or the Idaho Rural Water Association.

## **Assistance**

Public water supplies and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.

Idaho Falls Regional DEQ Office     (208) 528-2650

State DEQ Office                             (208) 373-0502

Website: <http://www2.state.id.us/deq>

Water suppliers serving fewer than 10,000 persons may contact John Bokor, Idaho Rural Water Association, at 1-800-962-3257 for assistance with drinking water protection (formerly wellhead protection) strategies.



## POTENTIAL CONTAMINANT INVENTORY LIST OF ACRONYMS AND DEFINITIONS

**AST (Aboveground Storage Tanks)** – Sites with aboveground storage tanks.

**Business Mailing List** – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

**CERCLIS** – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as ASuperfund, is designed to clean up hazardous waste sites that are on the national priority list (NPL).

**Cyanide Site** – DEQ permitted and known historical sites/facilities using cyanide.

**Dairy** – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

**Deep Injection Well** – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

**Enhanced Inventory** – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

**Floodplain** – This is a coverage of the 100-year floodplains.

**Group 1 Sites** – These are sites that show elevated levels of contaminants and are not within the priority one areas.

**Inorganic Priority Area** – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

**Landfill** – Areas of open and closed municipal and non-municipal landfills.

**LUST (Leaking Underground Storage Tank)** – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

**Mines and Quarries** – Mines and quarries permitted through the Idaho Department of Lands.)

**Nitrate Priority Area** – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

**NPDES (National Pollutant Discharge Elimination System)** – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

**Organic Priority Areas** – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

**Recharge Point** – This includes active, proposed, and possible recharge sites on the Snake River Plain.

**RICRIS** – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

**SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities)** – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

**Toxic Release Inventory (TRI)** – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

**UST (Underground Storage Tank)** – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

**Wastewater Land Applications Sites** – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

**Wellheads** – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

**NOTE:** Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.

## References Cited

- Ackerman, D.J., 1995, Analysis of Steady-State Flow and Advective Transport in the Eastern Snake River Plain Aquifer System, Idaho, U.S. Geological Survey Water-Resources Investigations Report 94-4257, I-FY95, 25 p.
- Cosgrove, D.M., G.S. Johnson and S. Laney, 1999, Description of the IDWR/UI Snake River Plain Aquifer Model (SRPAM), Idaho Water Resources Research Institute, 95 p.
- DeSonneville, J.L.J., 1972, Development of a Mathematical Groundwater Model: Water Resources Research Institute, University of Idaho, Moscow, Idaho, 227 p.
- Garabedian, S.P., 1992, Hydrology and Digital Simulation of the Regional Aquifer System, Eastern Snake River Plain, Idaho, U.S. Geological Survey Professional Paper 1408-F, 102 p.
- Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. "Recommended Standards for Water Works."
- Idaho Department of Agriculture, 1998. Unpublished Data.
- Idaho Department of Environmental Quality, 1997. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.
- Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.
- Lindholm, G.F., 1996, Summary of the Snake River Plain Regional Aquifer-System Analysis in Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-A, 59 p.
- Whitehead, R.L., 1992, Geohydrological Framework of the Snake River Plain Regional Aquifer System, Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-B, I-FY92, 32 p.

## Attachment A

# Township Park Water Company Susceptibility Analysis Worksheets

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.2)
- 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.375)

Final Susceptibility Scoring:

0 - 5    Low Susceptibility

6 - 12   Moderate Susceptibility

≥ 13    High Susceptibility

1. System Construction		SCORE			
Drill Date	07/02/1991				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1996			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	YES	0			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		2			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		6			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high	YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	77	74	69	34
(Score = # Sources X 2 ) 8 Points Maximum		8	8	8	8
Sources of Class II or III leacheable contaminants or 4 Points Maximum	YES	12	31	33	
Zone 1B contains or intercepts a Group 1 Area	YES	4	4	4	
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land		0	0	2	0
		4	4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		16	16	18	12
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	YES	2	2	2	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Land Use Zone II Greater Than 50% Irrigated Agricultural Land		2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		5	5	5	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	YES	1	1	1	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		2	2	2	0
Cumulative Potential Contaminant / Land Use Score		27	25	29	14
4. Final Susceptibility Source Score		13	13	14	13
5. Final Well Ranking		High	High	High	High

1. System Construction		SCORE			
Drill Date	07/02/1991				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1996			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	YES	0			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		2			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		6			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high	YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	77	74	69	34
(Score = # Sources X 2 ) 8 Points Maximum		8	8	8	8
Sources of Class II or III leacheable contaminants or 4 Points Maximum	YES	12	31	33	
		4	4	4	
Zone 1B contains or intercepts a Group 1 Area	YES	0	0	2	0
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land		4	4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		16	16	18	12
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	YES	2	2	2	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Land Use Zone II Greater Than 50% Irrigated Agricultural Land		2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		5	5	5	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	YES	1	1	1	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		2	2	2	0
Cumulative Potential Contaminant / Land Use Score		27	25	29	14
4. Final Susceptibility Source Score		13	13	14	13
5. Final Well Ranking		High	High	High	High